



CERTIFICATE OF CONSTANCY OF PERFORMANCE

1783-CPR-1639

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cable Type : 052XZ1-F

Reaction to Fire Performance: Cca, s1a, d2, a1

Power cables used in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

(SCOPE IS AT THE ATTACHMENT)

placed on the market under the name or trade mark of

ÖZNR KABLO SAN.VE TİC.A.Ş.
ÖMER AVNİ MAH. MECLİS-İ MEBUSAN CAD. ÖZNR PLAZA NO:73 /6
BEYOĞLU-İSTANBUL

and produced in the manufacturing plant

ÖZNR KABLO SAN.VE TİC.A.Ş.
ÇERKEZKÖY O.S.B. GAZİOSMANPAŞA MAH. 5. CAD. NO:23
ÇERKEZKÖY-TEKİRDAĞ

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 50575: 2014 + A1: 2016

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product .

This certificate was first issued on 29.04.2026 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Dr. Alkan HAFÇI
Deputy Director of Directives



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION



ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

PRODUCT DESCRIPTION:

Designation of cable family	052XZ1-F
Rated voltage	300/500 V

RELEVANT CONSTRUCTIONAL INFORMATION:

Conductor design	Circular
Conductor class	5
Number of cores	Multicore
Screen	Not Include
Armour	Not Include
Outer Sheath	HFFR Compound

ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE EN 50576:

Covered field
<input type="checkbox"/> Armoured
<input checked="" type="checkbox"/> Unarmoured multicore
<input type="checkbox"/> Single core sheathed
<input type="checkbox"/> Single core unsheathed
<input type="checkbox"/> Cable family including diameter $\leq 5\text{mm}$

CROSS-SECTIONS IN THE SCOPE:

Number of cores	Cross-section mm ²
2	0,75-1,0-1,5-2,5-4-6
3	0,75-1,0-1,5-2,5-4-6
4	0,75-1,0-1,5-2,5-4-6
5	0,75-1,0-1,5-2,5-4-6

CABLE PARAMETER RANGE

$\chi = 18-70$

OUTER DIAMETER RANGE:

$D = 6,5-16,4\text{mm}$



Attachment of the Certificate of Constancy of Performance, 1783-CPR-1639