



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1783-CPR-710

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation-CPR), this certificate applies to the construction product

produced by

ÖZNUR KABLO SANAYİ VE TİCARET A.Ş.

and produced in the manufacturing plant

ÇOSB GAZİ OSMAN PAŞA MAH. 5. CADDE NO:23 ÇERKEZKÖY / TEKİRDAĞ

defined as

Cable type : N2XH

Reaction to fire performance: Cca, s1a, d2, a1

(SCOPE IS AT THE ATTACHMENT)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 50575: 2014 + A1: 2016

1783

under **system 1 +** for the performances set out in this certificate are applied and that

the construction product fulfils all the prescribed requirements for these performances

This certificate was first issued on 19.10.2017 under CPR-Construction Products Regulation and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the certification body.

19.10.2017 Rev.0



Volkan GÜLEÇ
Deputy Director of Directives



TÜRK STANDARDLARI ENSTİTÜSÜ

TURKISH STANDARDS INSTITUTION

ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

PRODUCT DESCRIPTION:

Designation of cable family	N2XH
Rated voltage	0,6/1 kV

RELEVANT CONSTRUCTIONAL INFORMATION:

Conductor design	Round
Conductor class	1/2
Number of cores	Single core
Concentric shield	Does not include
Armour	Does not include

ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE TS CLC TS 50576:

Covered field
<input type="checkbox"/> Armoured
<input type="checkbox"/> Unarmoured multicore
<input checked="" type="checkbox"/> Single core sheathed
<input type="checkbox"/> Single core unsheathed
<input type="checkbox"/> Cable family including diameter \leq 5mm

CROSSECTIONS IN THE SCOPE:

Number of cores	Cross-sections mm ²
1	10-16-25-35-50-70-95-120-150-185-240

Attachment of the Certificate of Constancy of Performance, 1783-CPR-710.



www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or erased for misunderstanding.