



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
TURKISH STANDARDS INSTITUTION

**CERTIFICATE OF CONSTANCY OF PERFORMANCE**

**1783-CPR-713**

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation-CPR), this certificate applies to the construction product

produced by

**ÖZNUR KABLO SANAYİ VE TİCARET A.Ş.**

and produced in the manufacturing plant

**ÇOSB GAZİ OSMAN PAŞA MAH. 5. CADDE NO:23 ÇERKEZKÖY / TEKİRDAĞ**

defined as

**Cable type : NHXMH**

**Reaction to fire performance: B2ca, s1a, d1, a1**

**(SCOPE IS AT THE ATTACHMENT)**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 50575: 2014 + A1: 2016**

**1783**


under **system 1 +** for the performances set out in this certificate are applied and that

**the construction product fulfils all the prescribed requirements for these performances**

This certificate was first issued on 19.10.2017 under CPR-Construction Products Regulation and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the certification body.

19.10.2017



  
Volkan GÜLEÇ  
Deputy Director of Directives

[www.tse.org.tr](http://www.tse.org.tr) / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıntı ve silinti yapılamaz.  
This certificate cannot be altered, partially duplicated or creased for misunderstanding.



# TÜRK STANDARDLARI ENSTİTÜSÜ

TURKISH STANDARDS INSTITUTION

## ATTACHMENT OF THE CERTIFICATE OF CONSTANCY OF PERFORMANCE

### PRODUCT DESCRIPTION:

Designation of cable family	NHXMH
Rated voltage	300/500 V

### RELEVANT CONSTRUCTIONAL INFORMATION:

Conductor design	Round
Conductor class	1/2
Number of cores	Multicore
Concentric shield	Does not include
Armour	Does not include

### ELECTRIC CABLES-EXTENDED APPLICATION OF TEST RESULTS FOR REACTION TO FIRE TS CLC TS 50576:

Covered field	
<input type="checkbox"/>	Armoured
<input checked="" type="checkbox"/>	Unarmoured multicore
<input type="checkbox"/>	Single core sheathed
<input type="checkbox"/>	Single core unsheathed
<input type="checkbox"/>	Cable family including diameter $\leq$ 5mm

### CROSSECTIONS IN THE SCOPE:

Number of cores	Cross-sections mm <sup>2</sup>
2	1,5-2,5-4-6-10
3	1,5-2,5-4-6-10-16
4	1,5-2,5-4-6-10-16
5	1,5-2,5-4-6-10-16

Attachment of the Certificate of Constancy of Performance, 1783-CPR-713.



[www.tse.org.tr](http://www.tse.org.tr) / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazıma ve silinti yapılamaz.  
This certificate cannot be altered, partially duplicated or erased for misunderstanding.