


**STEEL REINFORCED ALUMINIM CONDUCTORS (ACSR)**


<b>Code</b>	ACSR
<b>Standards</b>	TS EN 50182, TEDAŞ MYD/96-014
<b>Construction</b>	Steel rods covered by uninsulated Aluminum conductors
<b>Applications</b>	Used in areas not available for underground cable transmission, in open areas where the cost of using underground cables is high, at low and high voltage aerial lines.

Type	Section	Aluminum Cross Section	Steel Cross Section	Total Section	AWG Section	Number of Steel Rods	Diameter of Steel Rods	Number of Alum.	Twist Diam. Of Conductor
		mm <sup>2</sup>	mm <sup>2</sup>	mm <sup>2</sup>		Num.	mm	Num.	mm
TUHRUS	17/3	16,83	2,80	19,63	5	1	1,89	6	5,67
SWAN	21/4	21,18	3,53	24,71	4	1	2,12	6	6,36
SWALLOW	27/4	26,69	4,45	31,14	3	1	2,38	6	7,14
SPARROW	34/6	33,59	5,60	39,19	2	1	2,67	6	8,01
ROBIN	42/7	42,41	7,07	49,48	1	1	3,00	6	9,00
RAVEN	54/9	53,52	8,92	62,44	1/0	1	3,37	6	10,11
QUALL	67/11	67,33	11,22	78,55	2/0	1	3,78	6	11,34
PIGEON	85/14	85,12	14,18	99,30	3/0	1	4,25	6	12,75
WAXWING	135/7	134,98	7,50	142,48	266800	1	3,09	18	15,45
PARTRIGE	135/22	134,87	21,99	156,86	266800	7	2,00	26	16,28
PHEOBE	152/8	152,09	8,45	160,54	300000	1	3,28	18	16,40
OSTRICH	152/25	152,19	24,71	176,90	300000	7	2,12	26	17,28
HAWK	242/39	241,65	39,19	280,84	477000	7	2,67	26	21,77
DRAKE	403/65	402,56	65,44	468,00	795000	7	3,45	26	28,11
CARDİNAL	485/63	484,53	62,81	547,34	954000	7	3,38	54	30,42
PHEASANT	645/82	645,08	81,71	726,79	1272000	19	2,34	54	35,10