

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60152161

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>	<i>(day/mo/yr)</i>
	0001--19600424 001	18.11.2020	

Genehmigungsinhaber *License Holder*

ÖZNUR KABLO SAN. VE TİC. A.Ş.
ŞAİR ZİYA PAŞA CAD. NO:41
KARAKÖY
34425 İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

ÖZNUR KABLO SAN. VE TİC. A.Ş.
Ç.O.S.B GAZİOSMANPAŞA MAH.5.CAD NO:23
ÇERKEZKÖY
TEKİRDAĞ
Türkiye

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111230247

Geprüft nach *Tested acc. to*
EN 50618:2014

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit
License Fee - Unit

Cable Electric Cables for Photovoltaic Systems

Code designation:	H1Z2Z2-K	22
Cross section:	Between 1,5 mm ² to 95 mm ² acc. to IEC 60228:2004 Table 3	
Trade mark:	Öznur kablo	
Rated Voltage:	AC 1,0/1,0 kV; DC 1,5 kV Conductor-conductor Conductor-earth	
Ambient temperature:	-40°C to +90°C	
Max. Conductor temp.:	+120°C (for 20.000h)	
Material of insulation:	Halogen free low smoke flame retardant cross-linked polyolefin compound	
Material of sheath:	Halogen free low smoke flame retardant cross-linked polyolefin compound	
Color of insulation:	White	
Color of sheath:	Black and Red	

22

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

